कार्यकारी अभियंता,
सा.बां.विभाग क्रं.१, पी.डब्ल्यू.डी.आवार,
स्टेशन रोड, ठाणे-४००६०१.

माहितीचा अधिकार

- www. mahapwd.com | - eethanepwdivision@gmail.com | २५३६९२९३
Visit at : www. thanepwd.org

जा.क्र./साबांवि-१/रेखा शाखा/ १८२६ दिनांक: 21/2/2023

प्रति,
यशवंतराव चव्हाण,
इंग्लिश मिडीयम स्कुल,
कोपरखैरणे,नवी मुंबई.

विषय : नॅशनल बिल्डींग कोड-२००५ इमारत सुरक्षित असल्याबाबतचा दाखला देणेबाबत.
(यशवंतराव चव्हाण,कोपरखैरणे,नवी मुंबई.जि.ठाणे.)

संदर्भ : १) यशवंतराव चव्हाण,कोपरखैरणे,नवी मुंबई.जि.ठाणे.यांचे पत्र क्र.१३१७ दि.२१/०२/२०२३ रोजीचे पत्र.
२) उपविभागीय अभियंता सा.बां.उपविभाग.क्र-३ .यांचे पत्र.जा.क्रं./ साबांउविक्र-३/व.लि / ११७दिनांक-२३/०२/२०२३ रोजीच पत्र.

उपरोक्त संदर्भिय विषयानुसार आपण सादर केलेल्या अवेदन पत्रा नुसार **यशवंतराव चव्हाण,कोपरखैरणे,नवी मुंबई.जि.ठाणे.)** आपल्या संस्थेची. शालेय इमारतीची या विभागाच्या अधिपत्याखालील उपविभागीय अभियंता सा.बां.उपविभाग, कल्याण यांनी दिनांक १०/०२/२०२३ रोजी पाहाणी केली आहे त्यांनी सादर केलेल्या पाहणी अहवालाच्या आधारे,तसेच प्रमाणपत्रातील अटींवर शालेय इमारत सुरक्षित असल्याबाबतचे प्रमाणपत्र प्रतीस्वाक्षरी करून. आपल्या माहितीसाठी व आवश्यक त्या कार्यवाहीसाठी देण्यात येत आहे.

सोबत-इमारत सुरक्षितता प्रमाणपत्र .

कार्यकारी अभियंता
सा.बां.विभाग क्रं.१, ठाणे

D:\डी.बी\शाळा.docx

Scanned with OKEN Scanner

BUILDING STABILITY CERTIFICATE

Certified that Educational building belonging to the Yashwantrao Chavan English Medium School, Plot No. 23, Sector-15, Koparkhairane, Navi Mumbai, Tal. & Dist. Thane has been inspected by this office on dated 10/02/2023. At time of the inspection of such educational building is seems sound and stable enough to bear the maximum load of 40 Nos of students per class room of the existing 23 Nos. of Class rooms & it will be stable to bear the existing live load for building is used for school purpose as on date, except in the case of natural calamity.

It is also certify that the following general terms and conditions may be full fill by the management in the stipulated period.

1. Toilet, W.C. etc. shall be kept clean for its purpose of use .
2. Adequate fire fighting arrangement should be kept for its full period of use and should be renewed twice in a year.
3. Firefighting equipment shall be suitably located and clearly marked.
4. There should be sufficient light and ventilation in the Building.
5. Essential requirements for electrical installation in building to ensure sufficient use of electricity including safety from fire and shock.
6. If any fault or alteration occurred in Building the certificate will be cancelled automatically.

This Certificate is valid for one year from the date of issue and it will be renew time to time every year before expiry date.

The necessary inspection Fees Rs. 1000/- (Rupees One Thousand Only) paid by the management vide Challan No. D.R. No.0247369 dated 10/02/2023 and it is credited on account of 0059 P.W. remittances into treasury S.B.I at Thane.

This Certificate is valid upto date 31/12/2023

Sub Divisional Engineer,
P.W. Sub Div. No. 3,
Thane.

Counter Signed

Executive Engineer,
P.W. Division No. 1,
Thane.

EXECUTIVE ENGINEER'S OFFICE P.W.D. DIVN. THANE

Scanned with OKEN Scanner