



# GANGA FIRE SAFETY

Add.: Plot No. 131, Office No. 01, Sector-19A, Koparkhairane, Navi Mumbai - 400 709.  
Mob.: 9820556896 / 9987490609 Email : gangafiresafety2012@gmail.com Web : www.gangafiresafety.in

Ref No. GFS/22/357

Date: 22 August 2022

Govt. Approved Licensed

## B FORM CERTIFICATE

*Six Month certificate to be given on January & July by the owner or occupier for Compliance of the fire prevention & life safety measures.*

### CERTIFICATE

Certified that I/We have carried out inspection of the fire prevention & life safety measures installed in the following building or premises, Namely: **M/S.- Vashwant Rao Chavan English Medium School , Sector -15, Plot No.-23, Koperkhairane , Navi Mumbai -400709**

I/We Further certify that these installation in the above-mentioned building are maintained in good repair & efficient conditions.

During the period Jan to June 2022 (Six Month) as required under the provisions of the Maharashtra Fire Prevention & Life Safety Measures Act, 2006(Mah III of 2007) the details of the inspection of installation carried out by me/us are mentioned in the report appended herewith

#### License No.

- 1) Maharashtra Fire Services License No. MFS / LA / RF-410
- 2) Maharashtra Fire Services License No. MFS / LA / RF-404

For Ganga Fir Safety

NEERAJ  
DUBEY

Digitally signed by  
NEERAJ DUBEY  
Date: 2022.08.18  
21:31:06 +05:30

Authorised Signatory



# GANGA FIRE SAFETY

Add.: Plot No. 131, Office No. 01, Sector-19A, Koparkhairane, Navi Mumbai - 400 709.

Mob.: 9820556896 / 9987490609 Email : gangafiresafety2012@gmail.com Web : www.gangafiresafety.in

Date: 22/08/2022

M/S. -Yashwant Rao Chavan English Medium School ,Plot No-23,Sector-15,Koperkhairane  
,Navi Mumbai-400709 ( G+ 3<sup>rd</sup> Floor)

Sub :Details of work and related activities , Which we have performed are mentioned  
as appended below.

| Sr No | Equipments  | Quantity |
|-------|---|----------|
| 01    | 100 MM dia wet riser cum down corner pipe line with isolation valve for Hydrant system. | 03 Nos   |
| 02    | Landing Hydrant valve   | 08 Nos   |
| 03    | Hose Box Single door  | 06 Nos   |
| 04    | First Aid Hose Reel with Rubber Pipe and Shutt Off Nozzle                               | 08 Nos   |
| 05    | GM Nozzle/Branch Pipe 2.1/2"  | 06Nos    |
| 06    | Canvas Hose Pipe With M/F Coupling  | 06 Nos   |
| 07    | Court Yard Hydrant valve  | 06 Nos   |
| 08    | Siamese connection With Valves & Fixture  | 01 Nos   |
| 09    | Booster Pump 5 Hp   | 01Nos    |
| 10    | Jockey Pump 7.5 Hp  | 01Nos    |
| 11    | Main Pump 25Hp  | 01Nos    |
| 12    | Over Head water Tank  | 01Nos    |
| 13    | Under Ground Water Tank   | 01Nos    |
| 14    | Co2 4.5 Kg Fire Extinguisher  | 01Nos    |
| 15    | Co2 3Kg Fire Extinguisher   | 01Nos    |
| 16    | ABC 5 Kg Fire Extinguisher  | 05 Nos   |
| 17    | ABC 4 Kg Fire Extinguisher  | 04 Nos   |
| 18    | Fire Alarm Panel  | 01 Nos   |
| 19    | MCP/Hooter  | 04 Nos   |

Yours faithfully,

For Ganga Fire safety.

(Authorised Signature)

NEERAJ  
DUBEY

Digitally signed by  
NEERAJ DUBEY  
Date: 2022.08.18  
21:15:06 +05'30'



**Govt. of Maharashtra**  
**Directorate of Maharashtra Fire Service**  
Vidyanagri, Hans Bhugra Marg, Santacruz (East),  
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666  
www.mahafireservice.gov.in

**FORM N**  
**[ ( See section 9 (3) and rule 14 )**  
**License to act as a License Agency for the purpose of**  
**Fire Prevention and Life Safety Measure**

License No. MFS / LA / RF-410 / RD- 404

Date: 30.07.2022

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Ganga Fire Safety** having their registered office at **Plot No. 131, Office No. 01, Sector 19A, Koparkhairne, Navi Mumbai 400709** and their contact details are Office Number: 9820556896 and Email ID: gangafiresafety2012@gmail.com with PAN registration No. AAOFG3236A and GST No. 27AAOFG3236A1ZO to act as a Licensed Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

1. Fire Fighting and Sprinkler System: Class D
2. Detection and Fire Suppression System: Class D

**M/s. Ganga Fire Safety** shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **30.07.2022 to 29.07.2023**

Hatyal  
Kiran  
Asst Director

Digitally signed  
by Hatyul Kiran  
Date: 2022.08.05  
21:34:43 +05'30'

**NEERAJ DUBEY**  
Digitally signed by  
NEERAJ DUBEY  
Date: 2022.08.05  
17:59:41 +05'30'

**SANTOSH  
SHRIDHAR  
WARICK**

Digitally signed by  
SANTOSH SHRIDHAR  
WARICK  
Date: 2022.08.06 09:55:55  
+05'30'

**( S S Warick )**  
Director  
Maharashtra Fire Service

Digital Signature of Authorized Person to sign Form A or Form B

Note:

\* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.